

Instructions: Complete pages 1 and 2 of this form and submit to your local health department within 10 days of the close of the reporting month.

Complete page 3 if your system utilizes conventional or direct filtration and can answer "YES" to any of the four questions on page 3.

Public Water System Name		Reporting Month/Year		Type of Filtration								
High Falls Water District		October 2023		Conventional sand filtration								
Public Water System ID Number		Town, Village, or City									County	
55030250		Marbletown									Ulster	
Date	Entry Point Chlorine Residual (mg/L)						Distribution System Results					
	0	400	800	1200	1600	2000	Sample Location	(Cl ₂)	(NTU)			
1			1.61									
2			1.34				176 Mohonk Rd.	1.36	0.09			
3			1.21				213 meter pit	1.08	0.29			
4			1.51				School hill, meter pit	0.67	0.29			
5			1.48				72 old Route 213	0.81	0.2			
6			0.70				10 firehouse	0.91	0.27			
7			1.19									
8			1.30									
9			1.48				176 Mohonk Rd.	1.1	0.3			
10			1.13				72 old Route 213	0.72	0.26			
11			1.06				213 meter pit	0.73	0.27			
12			0.88				Barbershop	0.37	0.29			
13			0.98				10 Firehouse Rd.	0.46	0.26			
14			1.80									
15			5.00									
16			4.34				176 Mohonk Rd.	1.31	0.08			
17			3.80				Barbershop	0.41	. 25			
18			3.20				School hill, meter pit	0.38	0.28			
19			2.00				10 Firehouse Rd.	1.8	0.24			
20			1.73				72 old Route 213	1.06	0.28			
21			1.52									
22			1.46									
23			1.42				176 Mohonk Rd.	1.55	0.11			
24			0.95				72 old Route 213	0.90	0.24			
25			0.46				10 Firehouse Rd.	1.31	0.21			
26			0.59				213 meter pit	1.33	0.29			
27			0.39				School hill, meter pit	1.29	0.25			
28			0.40									
29			0.20									
30			4.99				176 Mohonk Rd.	0.25	0.13			
31			2.83				213 meter pit	0.35	0.35			

Monthly Turbidity Average

Location of entry point High Falls treatment Plant

Population served 426

Entry point disinfection monitoring:

If Grab, how many samples per day?

Monitoring results:

Did the entry point residual fall below 0.2 mg/L for more than 4 hours?.....

Did the monthly average of the distribution system turbidity results exceed 5 NTU?.....

Reported by (print name) Stephen Landell

Title Operator

NYSDOH Operator Certification Number NY0040651

Operator Grade Level 2A

Signature 

Date 11/12/23

